

URL used by Facilities

<https://biotech.alc.emcs.cornell.edu/>

David Neish and other staff in Building Services use this log-in web page to access HVAC-related real-time data for Cornell's buildings.

\$7/cuft, average.

300cuft flow rate for 250 Baker Lab.

- If hooded lab-space, would be ~1,500cuft.

3-4 full-room air exchanges per day, for 250 Baker Lab.

- For a lab, closer to twice(?) that.