

StaRS Filter Slotted Pipe Upgrade

StaRS Filter Slotted Pipe Upgrade

The SOSPU Team aims to decrease clogging in the slotted pipe outlet manifolds in filter by increasing the slot size. SOSPU recommends that APP changes to 0.012" slot width instead of 0.008" as this would prevent clogging by clay and coagulant, while keeping sand inside the filter.

Current & Future Research

Summary and links to relevant resources.




Team Members

Anna Doyle

Julia Timko

Natalie Mottl

Team Documents

	Symposium Presentation	Final Report	Final Presentation
Fall '17			

Past Research

None.